Bacteriological and Chemical Testing

Hillside, New Jersey 07205

410 Hillside Avenue



Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370418016.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Harvey Klein, M.S., Laboratory Director REPORT OF

TO: Alpha School

Mathew Klein, M.S., Founder (1916-1996)

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ANALYSIS

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM 219 SINK

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 08:28

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-15:22
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

Bacteriological and Chemical Testing

Hillside, New Jersey 07205

410 Hillside Avenue



Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370418015.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Harvey Klein, M.S., Laboratory Director REPORT OF **ANALYSIS**

TO: Alpha School 2210 West County Line Road

Mathew Klein, M.S., Founder (1916-1996)

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM 213 SINK

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 08:24

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-15:07
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			D	

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205



REPORT # 370418014.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: TEACHER'S LOUNGE SINK

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 08:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-15:04
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	+			

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370418013.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ADL ROOM SINK

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 08:16

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-15:01
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			
3.0				

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205 Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370418012.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF ANALYSIS

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: 2ND FLOOR WATER FOUNTAIN

DATE SAMPLED: 4/18/2017 TIME SAMPLED: 08:12

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:59
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205 Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966

email: info@gslabs.com Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF ANALYSIS

> > REPORT # 370418011.0 CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM PRE-K 1

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 08:07

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:56
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Difution Factor	None			
Digested (Y/N)	No			
	+			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

Hillside, New Jersey 07205

410 Hillside Avenue



Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370418010.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Harvey Klein, M.S., Laboratory Director REPORT OF **ANALYSIS**

TO: Alpha School

Mathew Klein, M.S., Founder (1916-1996)

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ROOM PRE-K 2

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 08:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:53
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	++			

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey 07

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370418008.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: SCHOOL OFFICE CONFERENCE ROOM

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:47
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None		-	
Digested (Y/N)	No			
Digested (TM)	110		.	
			1	
				
			-	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director illside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370418007.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

REPORT OF ANALYSIS

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: 1ST FLOOR WATER FOUNTAIN

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 07:45

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:44
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Difution Factor	None			
Digested (Y/N)	No			
				-

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE PROPERTY OF THE PARTY OF TH

Mathew Klein, M.S., Founder (1916-1996)

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370418006.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

Harvey Klein, M.S., Laboratory Director

REPORT OF

ANALYSIS

TO: Alpha School 2210 West County Line Road Suite 2

Jackson

- 14 1 0

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: RKS OFFICE SINK

DATE SAMPLED: 4/18/2017 TIME SAMPLED: 07:41

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:41
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			Ì	
				+

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com

REPORT # 370418005.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

REPORT OF ANALYSIS

TO: Alpha School

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: FIELD BLANK

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 07:36

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	4/19/17-14:33
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Difution Factor	None			
Digested (Y/N)	No			

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com

REPORT # 370418009.0

CLIENT # ALP18

DATE SUBMITTED: 4/18/2017

REPORT OF **ANALYSIS**

TO: Alpha School

2210 West County Line Road

Suite 2

Jackson

NJ 08527

ATT: Mark Costa

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: NURSE'S OFFICE SINK

DATE SAMPLED: 4/18/2017

TIME SAMPLED: 07:56

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.9	ug/l	15	4/19/17-14:50
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p> MCL = Maximum Contaminant Level allowed by State and Federal regulations.